## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

**LISTING No.** 7125-1501:135 Page 1 of 1

**CATEGORY**: Fire Alarm Devices for the Hearing Impaired

**LISTEE**: Edwards, 90 Fieldstone Ct., Cheshire, CT 06410

Contact: Dave Mazur (203) 699-3155

DESIGN: Model Beacon Strobe Light Subassemblies. Cat. No. 105DHISTC-FJ Strobe Base Lens

(Electronic/Optic); Cat. No. 105BM Mounting Bracket (Elbow Extension); Cat. No. 105PM Pipe Mount Attachment (Pendant Mount); Cat. No. 105BX Outlet Box Attachment (Ceiling/Wall

Mount).

The complete assembled strobe light consists of a Cat. No 105DHIST assembled to a Cat. No. 105BX or a Cat. No. 105BM, with or without an elbow extension Cat. No. 105BM. Suitable for

indoor use.

The devices also employ a circuit board containing electrical components with a gas discharge tube that flashes approximately 65 times per minute. All electrical components are housed

inside the strobe base/lens subassembly.

Refer to listee's data sheet for additional detailed product description and operational

considerations.

**RATING**: Electrical: 20 – 30 VDC

Candela: 24cd wall

26cd ceiling

**INSTALLATION**: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical/candela rating, UL label, hazardous locations

classifications and Operating Temperature Code.

**APPROVAL**: Listed as Strobe light subassemblies for use in Class I, Division 2, Groups A, B, C, and D;

Class II, Division 2, Groups F and G; Class III, Hazardous Locations with Operating Temperature Code per marking and instructions; and intended for use with separately listed compatible fire alarm control units. For indoor use only. Assembled devices suitable for

hearing impaired application. Type 3R and 4X.

10-14-2002KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: OCTOBER 14, 2002 Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager